

Ass. Eng. No. 1	Total h's : 59852
-----------------	-------------------

Overhaul Cyl. Heads	Cyl. 1	Cyl. 2	Cyl. 3	Cyl. 4	Cyl. 5	Cyl. 6	Cyl. 7
Date	12-Dec-20	12-Dec-20	12-Dec-20	12-Dec-20	12-Dec-20	12-Dec-20	12-Dec-20
At working hours	59819	59819	59819	59819	59819	59819	59819
Service hours after overhaul	33	33	33	33	33	33	33

Overhaul Piston	Cyl. 1	Cyl. 2	Cyl. 3	Cyl. 4	Cyl. 5	Cyl. 6	Cyl. 7
Date	12-Dec-20	12-Dec-20	12-Dec-20	12-Dec-20	12-Dec-20	12-Dec-20	12-Dec-20
At working hours	59819	59819	59819	59819	59819	59819	59819
Service hours after overhaul	33	33	33	33	33	33	33

Cleaning LO cooler 01.04.16 45443

Overhaul Injectors	Cyl. 1	Cyl. 2	Cyl. 3	Cyl. 4	Cyl. 5	Cyl. 6	Cyl. 7
Date	12-Dec-20	12-Dec-20	12-Dec-20	12-Dec-20	12-Dec-20	12-Dec-20	12-Dec-20
At working hours	59819	59819	59819	59819	59819	59819	59819
every 2000 Hrs							
Service hours after overhaul	33	33	33	33	33	33	33

Adjusted inlet & exhaust valves clr at 58907 h (18/01/2020)

Overhaul Injector Pump	46661
Overhaul Turbocharger	16-Oct-16
At working hours	46661
Since last Overhaul	13191

46661

Overhaul Governor	12-Dec-20
At working hours	59819
Since last Overhaul	33
Replaced Gov. with new Unit	12/12/2020
Cleaned Oil Cooler	12-Dec-20
At working hours	59819
Since last Overhaul	33

46661

51930

Cleaning Generator 03.12.13 R/H 36381

Greasing inj. pp. drive	27-Oct-16
At working hours	46724
Since last Overhaul	13128
Governor oil changed	12-Dec-20
Since last Overhaul	33
Alternator bearings	26.03.2015
Oil changed	42356
Since last Overhaul	17496

59819

Prepared by doehleuser 02/02/2021

Aux. Eng. No. II	Total h's :	58323
------------------	-------------	-------

Overhaul Cyl. Heacs	Cyl. 1	Cyl. 2	Cyl. 3	Cyl. 4	Cyl. 5	Cyl. 6	Cyl. 7
Date	7-Dec-20	7-Dec-20	7-Dec-20	7-Dec-20	7-Dec-20	7-Dec-20	7-Dec-20
At working hours	67090	67090	67090	67090	67090	67090	67090
Service hours after overhaul	1233	1233	1233	1233	1233	1233	1233

Overhaul Piston	Cyl. 1	Cyl. 2	Cyl. 3	Cyl. 4	Cyl. 5	Cyl. 6	Cyl. 7
Date	7-Dec-20	7-Dec-20	7-Dec-20	7-Dec-20	7-Dec-20	7-Dec-20	7-Dec-20
At working hours	67090	67090	67090	67090	67090	67090	67090
Service hours after overhaul	1233	1233	1233	1233	1233	1233	1233

Overhaul Injectors	Cyl. 1	Cyl. 2	Cyl. 3	Cyl. 4	Cyl. 5	Cyl. 6	Cyl. 7
Date	7-Dec-20	7-Dec-20	7-Dec-20	7-Dec-20	7-Dec-20	7-Dec-20	7-Dec-20
At working hours	67090	67090	67090	67090	67090	67090	67090
Service hours after overhaul every 2000 Rh	1233	1233	1233	1233	1233	1233	1233

Cleaning Generator 02.12.13 R/H 40694

Generator bearings oil were changed 05.06.2014 42086
Adjusted inlet & exhaust valves clr at 63548 h (14/01/2020)

Overhaul Injector Pump	50636
Overhaul Turbocharger	7-Dec-20
At working hours	67090
Since last Overhaul	1233

50636

Overhaul Governor	50636
At working hours	52852
Since last Overhaul	1233

50636

52821

Oilcharge	7-Dec-20
At working hours	67090
Since last Change	1233

Replaced Gov. with new Unit

Cleaned Oil Cooler	7-Dec-20
At working hours	67090
Since last Overhaul	1233

Greasing inj. pp. drive	30-Sep-16
At working hours	50355
Since last Overhaul	17968
Governor oil changed	07-Dec-20
Since last Overhaul	1233
Alternator bearings	5-Jun-14
Oil changed	42086
Since last Overhaul	26237

Aux. Eng. No. III	Total h's : 54548
-------------------	-------------------

Overhaul Cyl. Heads	Cyl. 1	Cyl. 2	Cyl. 3	Cyl. 4	Cyl. 5	Cyl. 6	Cyl. 7
Date	3-Nov-16	3-Nov-16	3-Nov-16	3-Nov-16	3-Nov-16	3-Nov-16	3-Nov-16
At working hours	52938	52938	52938	52938	52938	52938	52938
Service hours after overhaul	11610	11610	11610	11610	11610	11610	11610

Overhaul Piston	Cyl. 1	Cyl. 2	Cyl. 3	Cyl. 4	Cyl. 5	Cyl. 6	Cyl. 7
Date	28-Aug-12	28-Aug-12	28-Aug-12	30-Aug-12	30-Aug-12	30-Aug-12	1-Sep-12
At working hours	43790	43790	43790	43790	43790	43790	43790
Service hours after overhaul	20758	20758	20758	20758	20758	20758	20758

Overhaul Injectors	Cyl. 1	Cyl. 2	Cyl. 3	Cyl. 4	Cyl. 5	Cyl. 6	Cyl. 7
Date	9-Jan-21	9-Jan-21	9-Jan-21	9-Jan-21	9-Jan-21	9-Jan-21	9-Jan-21
At working hours	64304	64304	64304	64304	64304	64304	64304
Service hours after overhaul every 2000 Rh	244	244	244	244	244	244	244

Cleaning Generator 01.12.13 R/H 45873

Adjusted inlet & exhaust valves clr at 61324 h (31.07.2020)

Overhaul Injector Pump	53581
Overhaul Turbocharger	20-Feb-11
At working hours	37764
Since last Overhaul	26784

53581

Overhaul Governor	4-Mar-08
At working hours	27897
Since last Overhaul	36651

50403

Greasing inj. pp. drive	13-Aug-15
At working hours	48680
Since last Overhaul	15863
Governor oil changed	24-Jan-20
Since last Overhaul	46777
Alternator bearings	4-Sep-15
Oil changed	48761
Since last Overhaul	15787

Oilchange	4-Apr-18
At working hours	55451
Since last Change	9097

Replaced Gov. with new Unit

Cleaned Oil Cooler	15-Feb-18
At working hours	55196
since last Overhaul	9352

Main Air Compr. I	Total hrs
	1590

Installing New compressor 12.10.2019

overhauled valves	
at running h's	0
since last Overhaul	1590

oilchange	
at running h's	0
since last change	1590

Main Air Compr. I	Total hrs
	799

Installing New compressor 19.08.2019

overhauled valves	
at running h's	0
since last Overhaul	799

oilchange	
at running h's	0
since last change	799

Main Air Comp. II	Total hrs
	1238

Installing New compressor 25.02.2020

overhauled valves	30-Sep-19
at running h's	0
since last Overhaul	1238

every 1000 h

oilchange	30-Sep-19
at running h's	0
since last change	1238

every 1000 h